



कार्यालय प्रयोगशाला (मु.), जलकल विभाग, नगर निगम आगरा

OFFICE OF LABORATORY, JALKAL VIBHAG, NAGAR NIGAM, AGRA

Chemical Water Analysis Test Report

Source of Sample — R.O.

Agency/Deptt.- S.D. Public School, Nikat Lal Singh Degree College, Pilipokhar, Khandoli, Agra-U.P.

Date and Time of Collection: 13-06-2025 (9:15 am)

Date and Time of Receipt 13-06-2025 (01:30 pm)

Sr. No	Parameters	IS : 10500 (2012)	Result	Unit
1	Turbidity	1.0-5.0	NIL	NTU/1
2	Colour	5.0-15.0	NIL	P.Scale
3	pH	6.5-8.5	7.34	-
4	Total Dissolved Solids (TDS)	500.2-2000.0	110	Mg/L
5	Total Hardness as CaCO ₃	200-600	70	Mg/L
6	Calcium Hardness	-	40	Mg/L
7	Magnesium Hardness	-	30	Mg/L
8	Total Alkalinity (M) as CaCO ₃	200.0-600.0	155	Mg/L
9	Chlorides	250.0-1000	NIL	Mg/L
10	Sulphate	200-400	NIL	Mg/L
11	Nitrates	45-100	NIL	Mg/L
12	Flourides	1.0-1.5	NIL	Mg/L
13	Calcium as Ca ⁺⁺	75.0-200.2	16.00	Mg/L
14	Magnicium as Mg ⁺⁺	30.0-100	7.32	Mg/L
15	Iron as Fe	0.30-1.0	NIL	Mg/L
16	Maganese	0.1-0.3	NIL	Mg/L

THE SAMPLE IS COLLECTED AND
DEPOSITED BY THE PARTY ITSELF

Bacteriological Test Report

			Result	
1	Coliform	NIL	NIL	CFU/100 MI
2	E.Coli	NIL	NIL	CFU/100 MI

Remark:- The result conforms to standard IS : 10500 (2012) hence potable.

Nisla Kapoor
Principal
S D Public School
Hathras Road Pilipokhar Agra-6

अनिल कुमार
Manager
S D Public School
Hathras Road Pilipokhar Agra-6

Chief Chemist
Jalkal Vibhag, Nagar Nigam, Agra

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 10Date: 19/06/25

It is certified that an inspection team headed by Dr. Nandan Singh
Dy. CMO (Name of Officers
 with designation) from office of the Chief Medical Officer Agra (Name of
 Department/Office) inspected the S.D. Public School
Hathras Road Pili Pokhar Agra - 283126 (Name & Address of
 the School) on S.D. Public School and found that the 17/06/25
S.D. Public School Hathras Road Pili Pokhar (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of 31 march 2026Signature with Seal: 19/06/25

Name

: Dr. Nandan Singh

Designation

: Dy. CMO

To

S.D. Public School
Hathras Road Pili Pokhar
Agra - 283126

(Name & Address of the Institution)

Nisha Kapoor

Principal
S D Public School
Hathras Road Pili Pokhar Agra-6

Manager
S D Public School
Hathras Road Pili Pokhar Agra-6